

# Fire tests on building materials and structures —

## Part 15: Method for measuring the rate of heat release of products

# Committees responsible for this British Standard

The preparation of this British Standard was entrusted by the Fire Standards Policy Committee (FSM/-) to Technical Committee FSM/21, upon which the following bodies were represented:

Association of Building Component Manufacturers  
 Association of Rooflights Manufacturers (ARMS)  
 Association of Specialist Fire Protection Contractors and Manufacturers  
 Autoclaved Aerated Concrete Products Association  
 British Carpet Manufacturers' Association Ltd.  
 British Floor Covering Manufacturers' Association  
 British Plastics Federation  
 British Railways Board  
 British Rigid Urethane Foam Manufacturers' Association  
 British Steel Industry  
 British Wood Preserving and Damp-proofing Association  
 Chemical Industries Association  
 Chief and Assistant Chief Fire Officers' Association  
 Department for Education  
 Department of the Environment (Building Research Establishment)  
 Department of the Environment (Central) (DCSS Fire Branch)  
 Department of the Environment (Construction Directorate)  
 Department of the Environment for Northern Ireland  
 Eurisol (UK) Mineral Wool Association  
 Fibre Cement Manufacturers' Association Limited  
 Flat Glass Manufacturers' Association  
 GAMBICA (BEAMA Ltd.)  
 Gypsum Products Development Association  
 Home Office  
 Institution of Fire Engineers  
 London Fire and Civil Defence Authority  
 Loss Prevention Council  
 National Council of Building Material Producers  
 National GRP Construction and Engineering Federation  
 Polyethylene Foam Insulation Association  
 Queen Mary and Westfield College  
 RAPRA Technology Ltd.  
 SGS United Kingdom Ltd.  
 Suspended Ceilings Association  
 Thermal Insulation Manufacturers' and Suppliers' Association (TISMA)  
 Timber Research and Development Association  
 Warrington Fire Research Centre  
 Wood Panel Products Federation  
 Wood Wool Slab Manufacturers' Association

This British Standard, having been prepared under the direction of the Fire Standards Policy Committee, was published under the authority of the Standards Board and comes into effect on 15 September 1993

© BSI 01-2000

The following BSI references relate to the work on this standard:  
 Committee reference FSM/21  
 Draft for comment 90/43558 DC

ISBN 0 580 22240 3

## Amendments issued since publication

Amd. No.	Date	Comments

# Contents

	Page
Committees responsible	Inside front cover
National foreword	ii
<hr/>	
Introduction	1
1 Scope	1
2 Normative references	1
3 Definitions	1
4 Symbols	2
5 Principle	2
6 Apparatus	3
7 Suitability of a product for testing	5
8 Specimen construction and preparation	5
9 Test environment	6
10 Calibration	6
11 Test procedure	7
12 Calculations	8
13 Test report	9
<hr/>	
Annex A (informative) Commentary and guidance notes for operators	21
Annex B (informative) Resolution, precision and bias	22
Annex C (informative) Mass loss rate and effective heat of combustion	24
Annex D (informative) Summary of test report	26
Annex E (informative) Calibration of the working heat flux meter	27
Annex F (informative) Calculation of heat release with additional gas analysis	27
Annex G (informative) Bibliography	30
<hr/>	
Figure 1 — Cross-sectional view through the heater	10
Figure 2 — Horizontal specimen holder	11
Figure 3 — Vertical specimen holder	12
Figure 4 — Exhaust system (not to scale)	13
Figure 5 — Overall view of apparatus	14
Figure 6 — Gas analyser instrumentation	15
Figure 7 — Exploded view, horizontal orientation	16
Figure 8 — Exploded view, vertical orientation	17
Figure 9 — Calibration burner	18
Figure 10 — Optional retainer frame	19
Figure 11 — Optional retaining grid	20
<hr/>	
List of references	Inside back cover
<hr/>	

## National foreword

This Part of BS 476 has been prepared under the direction of the Fire Standards Policy Committee. It is identical with ISO 5660-1:1993 *Fire tests — Reaction to fire — Part 1: Rate of heat release from building products (cone calorimeter method)*; published by the International Organization for Standardization (ISO).

**Cross references.** The Technical Committee has reviewed the provisions of ISO 554:1976, ISO/TR 3814:1989 and ISO IEC Guide 52:1990, to which normative reference is made in the text, and has decided that they are acceptable for use in conjunction with this standard.

**Textual errors.** When adopting the text of the International Standard, the following textual errors were discovered. They have been marked in the text and have been reported to the International Standards Organization in a proposal to amend the text of the International Standard.

In clause F.4, equation (F.9) should read as follows:

$$M_e = [4,5 + (1 - x_{H_2O}) (2,5 + x_{O_2} + 4x_{CO_2})] \times 4 \quad (F.9)$$

and equation (F.10) should read as follows:

$$\dot{q}(t) = 1,10 \left[ \frac{\Delta h_c}{r_O} \right] (1 - x_{H_2O}) \left[ \frac{x_{O_2}^0 (1 - x_{O_2} - x_{CO_2})}{1 - x_{O_2}^0 - x_{CO_2}^0} - x_{O_2} \right] \dot{m}_e \quad (F.10)$$

A British Standard does not purport to include all the necessary provisions of a contract. Users of British Standards are responsible for their correct application.

**Compliance with a British Standard does not of itself confer immunity from legal obligations.**

### Summary of pages

This document comprises a front cover, an inside front cover, pages i and ii, pages 1 to 30, an inside back cover and a back cover.

This standard has been updated (see copyright date) and may have had amendments incorporated. This will be indicated in the amendment table on the inside front cover.

## Introduction

Fire is a complex phenomenon: its behaviour and its effects depend upon a number of interrelated factors. The behaviour of materials and products depends upon the characteristics of the fire, the method of use of the materials and the environment in which they are exposed. The philosophy of reaction to fire tests is explained in ISO/TR 3814.

A test such as is specified in this International Standard deals only with a simple representation of a particular aspect of the potential fire situation typified by a radiant heat source and a spark. It cannot alone provide any direct guidance on behaviour or safety in fire. A test of this type may, however, be used for comparative purposes or to ensure the existence of a certain quality of performance (in this case heat release rates considered to have a bearing on fire performance generally). It would be wrong to attach any other meaning to performance in this test.

The term heat release rate is defined in ISO/IEC 52 Guide as the calorific energy released per unit time by a material during combustion under specified test conditions. It is one of the fundamental properties of fire and should almost always be taken into account in any assessment of fire hazard since it significantly affects the development of fire in a building.

This test is based on part of the ASTM standard E 1354. However, not all the equipment in E 1354 is the subject of this International Standard. Some of the additional instrumentation, in particular that measuring the properties of smoke and its rate of production, is the subject of discussion in ISO/TC 92.

This test does not rely upon the use of asbestos-based materials.

## 1 Scope

This International Standard specifies a method for assessing the heat release rate of essentially flat products exposed to controlled levels of radiant heating with or without an external igniter. The rate of heat release is determined by measurement of the oxygen consumption derived from the oxygen concentration and the flow rate in the combustion product stream. The time to ignition (sustained flaming) is also measured in this test. Products with surface irregularities may be tested according to specific requirements.

## 2 Normative references

The following standards contain provisions which, through reference in this text, constitute provisions of this part of ISO 5660. At the time of publication, the editions indicated were valid. All standards are subject to revision, and parties to agreements based on this part of ISO 5660 are encouraged to investigate the possibility of applying the most recent editions of the standards indicated below. Members of IEC and ISO maintain registers of currently valid International Standards.

ISO 554:1976, *Standard atmospheres for conditioning and/or testing — Specifications.*

ISO/TR 3814:1989, *Tests for measuring "reaction-to-fire" of building materials — Their development and application.*

ISO/IEC Guide 52:1990, *Glossary of fire terms and definitions.*

## 3 Definitions

For the purposes of this International Standard, the definitions given in ISO/IEC Guide 52 and the following definitions apply.

### 3.1 assembly

fabrication of materials or composites, for example sandwich panels

NOTE 1 This may include an air gap.

### 3.2 composite

combination of materials which are generally recognized in building construction as discrete entities, for example coated or laminated materials

### 3.3 essentially flat surface

surface whose irregularity from a plane does not exceed  $\pm 1$  mm

### 3.4 flashing

existence of flame on or over the surface of the specimen for periods of less than 1 s

### 3.5 ignition

onset of sustained flaming as defined in 3.12

### 3.6 irradiance (at a point of a surface)

quotient of the radiant flux incident on an infinitesimal element of surface containing the point, by the area of that element

NOTE 2 Convective heating is negligible in the horizontal specimen orientation. In the vertical orientation, it is small, but not negligible. Despite this contribution from convective heating, the term "irradiance" is used instead of "heat flux" throughout this International Standard as it best indicates the essentially radiative mode of heat transfer.

### 3.7

#### material

single substance or uniformly dispersed mixture, for example metal, stone, timber, concrete, mineral fibre, polymers

### 3.8

#### orientation

plane in which the exposed face of the specimen is located during testing, either vertical or horizontally face upwards

### 3.9

#### oxygen consumption principle

proportional relationship between the mass of oxygen consumed during combustion and the heat released

### 3.10

#### product

material, composite or assembly about which information is required

### 3.11

#### specimen

representative piece of the product which is to be tested together with any substrate or treatment

NOTE 3 This may include an air gap.

### 3.12

#### sustained flaming

existence of flame on or over the surface of the specimen for periods of over 4 s

### 3.13

#### transitory flaming

existence of flame on or over the surface of the specimen for periods of between 1 and 4 s

## 4 Symbols

$A_s$	initially exposed surface area of the specimen, expressed in square metres (m <sup>2</sup> )
$C$	calibration constant for oxygen consumption analysis, expressed in (m kg K) <sup>1/2</sup>
$\Delta h_c$	net heat of combustion, expressed in kilojoules per gram (kJ/g)
$\Delta h_{c,eff}$	effective net heat of combustion, expressed in kilojoules per gram (kJ/g)
$m$	mass of the specimen, expressed in kilograms (kg)
$m_f$	mass of the specimen at the end of the test, expressed in kilograms (kg)
$m_i$	mass of the specimen at sustained flaming, expressed in kilograms (kg)

$\dot{m}$	mass loss rate of the specimen, expressed in kilograms per second (kg/s)
$\dot{m}_e$	mass flow rate in exhaust duct, expressed in kilograms per second (kg/s)
$\Delta p$	orifice meter pressure differential, expressed in pascals (Pa)
$\dot{q}$	heat release rate, expressed in kilowatts (kW)
$\dot{q}''$	heat release rate per unit area, expressed in kilowatts per square metre (kW/m <sup>2</sup> )
$\dot{q}''_{max}$	maximum value of the heat release rate, expressed in kilowatts per square metre (kW/m <sup>2</sup> )
$\dot{q}''_{180}$	the average heat release rate over the period starting at $t_{ig}$ and ending 180 s later, expressed in kilowatts per square metre (kW/m <sup>2</sup> )
$\dot{q}''_{300}$	the average heat release rate over the period starting at $t_{ig}$ and ending 300 s later, expressed in kilowatts per square metre (kW/m <sup>2</sup> )
$q''_{tot}$	the total heat released during the entire test, expressed in megajoules per square metre (MJ/m <sup>2</sup> )
$r_o$	stoichiometric oxygen/fuel mass ratio
$t$	time, expressed in seconds (s)
$t_d$	delay time of the oxygen analyser, expressed in seconds (s)
$t_{ig}$	time to ignition (sustained flaming), expressed in seconds (s)
$\Delta t$	sampling time intervals, expressed in seconds (s)
$T_e$	absolute temperature of gas at the orifice meter, expressed in kelvin (K)
$x_{O_2}$	oxygen analyser reading, mole fraction of oxygen
$x_{O_2}^0$	initial value of oxygen analyser reading
$x_{O_2}^1$	oxygen analyser reading, before delay time correction

## 5 Principle

This test method is based on the observation that, generally, the net heat of combustion is proportional to the amount of oxygen required for combustion. The relationship is that approximately  $13,1 \times 10^3$  kJ of heat are released per kilogram of oxygen consumed. Specimens in the test are burned in ambient air conditions, while being subjected to a predetermined external irradiance within the range 0 kW/m<sup>2</sup> to 100 kW/m<sup>2</sup> and measurements are made of oxygen concentrations and exhaust gas flow rates.

The test method is used to assess the contribution that the product under test can make to the rate of evolution of heat during its involvement in fire. These properties are determined on small representative specimens.

## 6 Apparatus

### 6.1 General

The test apparatus shall be constructed as shown in Figure 5; a cross-section through the heater is shown in Figure 1 and an exploded view of horizontal and vertical orientations are given in Figure 7 and Figure 8. Untoleranced dimensions specified as critical shall have a tolerance of  $\pm 1$  mm.

All other dimensions are recommended values and should be followed closely.

**6.2 Cone-shaped radiant electric heater**, capable of horizontal or vertical orientation. The active element of the heater shall consist of an electrical heater rod, rated at 5 000 W at 240 V<sup>1)</sup>, tightly wound into the shape of a truncated cone (see Figure 1). The heater shall be encased on the outside with a double-wall stainless steel cone, packed with a refractory fibre material of approximately 100 kg/m<sup>3</sup> density. The irradiance from the heater shall be capable of being held at a preset level by means of a temperature controller and three, type K, stainless steel sheathed thermocouples, symmetrically disposed and in contact with, but not welded to, the heater element (see Figure 1). The thermocouples shall be of equal length and wired in parallel to the temperature controller. Either 3 mm outside diameter sheathed thermocouples with exposed hot junction or 1,0 mm to 1,6 mm outside diameter sheathed thermocouples with unexposed hot junction may be used. The heater shall be hinged so that it can be swung into either a horizontal or vertical orientation. The heater shall be capable of producing irradiances on the surface of the specimen of up to 100 kW/m<sup>2</sup>. The irradiance should be uniform within the central 50 mm  $\times$  50 mm area of the specimen, to within  $\pm 2$  % in the horizontal orientation and to within  $\pm 10$  % in the vertical orientation.

**6.3 Temperature controller**, capable of holding the element temperature steady to within  $\pm 2$  °C. A suitable system is a “3-term” controller (proportional, integral and derivative) and a thyristor unit capable of switching currents up to 25 A at 240 V. The controller should have a temperature input range of 0 °C to 1 000 °C, a set scale capable of being read to 2 °C or better and automatic cold junction compensation.

The thyristor unit shall be of the “zero-crossing” and not of the “phase-angle” type.

NOTE 4 A desirable feature is a control which, in the event of an open circuit in the thermocouple line, will either cause the power to fall to near the bottom of its range, or cut the power off.

The heater temperature shall be monitored by a meter capable of being read to  $\pm 2$  °C or better, it may either be separated or incorporated into the temperature controller.

**6.4 Load cell**, for measuring specimen mass loss. The load cell shall have an accuracy of 0,1 g and it should preferably have a measuring range of 500 g and a mechanical tare adjustment range of 3,5 kg.

**6.5 Specimen holders**, different for the two orientations.

**6.5.1** The horizontal specimen holder is shown in Figure 2. The bottom of the holder shall be lined with a layer of low density (nominal density 65 kg/m<sup>3</sup>) refractory fibre blanket with a thickness of at least 13 mm. The distance between the bottom surface of the cone heater and the top of the specimen shall be adjusted to 25 mm by using the sliding cone height adjustment (see Figure 1).

**6.5.2** The vertical specimen holder is shown in Figure 3 and includes a small drip tray to contain a limited amount of molten material. A specimen is installed in the vertical specimen holder by backing it with a layer of refractory fibre blanket (nominal density 65 kg/m<sup>3</sup>), the thickness of which depends on specimen thickness, but shall be at least 13 mm. A layer of rigid, ceramic fibre millboard shall be placed behind the fibre blanket layer. The millboard thickness shall be such that the entire assembly is rigidly bound together once the retaining spring clip is inserted behind the millboard. In the vertical orientation, the cone heater height is set so the centre lines up with the specimen centre.

<sup>1)</sup> This requires a 30 A supply.

**6.6 Exhaust gas system**, with flow measuring instrumentation.

**6.6.1** The exhaust gas system shall consist of a high temperature centrifugal exhaust fan, a hood, intake and exhaust ducts for the fan and an orifice plate flow meter (see Figure 4). The exhaust system shall be capable of developing flows from 0,012 m<sup>3</sup>/s to 0,035 m<sup>3</sup>/s.

**6.6.2** A restrictive orifice with an internal diameter of 57 mm shall be located between the hood and the duct to promote mixing.

**6.6.3** A ring sampler shall be located in the fan intake duct for gas sampling, 685 mm from the hood (see Figure 5). The ring sampler shall contain 12 small holes to average the stream composition with the holes facing away from the flow to avoid soot clogging.

**6.6.4** The temperature of the gas stream shall be measured using a 1,0 mm to 1,6 mm outside diameter sheathed-junction thermocouple or a 3 mm outside diameter exposed junction thermocouple positioned in the exhaust stack on the centre-line and 100 mm upstream from the measuring orifice plate.

**6.6.5** The flow rate shall be determined by measuring the differential pressure across a sharp edge orifice (internal diameter 57 mm) in the exhaust stack, at least 350 mm downstream from the fan, if the latter is located as shown on Figure 4.

**6.6.6** The geometry of the exhaust system is not so critical. Where necessary, small deviations from the recommended dimensions given in Figure 4 are allowed, for example, the inner diameter of the duct and the orifice plates can be slightly different. Also the fan does not need to be at the exact location as indicated on Figure 4, but may be located further downstream allowing for a more common type of fan to be used. In this case, undisturbed inflow distance to the gas sampling probe and the measuring orifice shall be sufficient for the flow to be uniformly mixed.

### **6.7 Gas sampling apparatus**

Gas sampling apparatus is shown in Figure 6 and incorporates a pump, a filter to prevent entry of soot, a cold trap to remove most of the moisture, a by-pass system set to divert all flow except that required for the oxygen analyser, a further moisture trap and, if CO<sub>2</sub> is not measured, a trap for CO<sub>2</sub> removal.

NOTE 5 If an (optional) CO<sub>2</sub> analyser is used, the equations to calculate the rate of heat release can be different from those for the standard case (see clause 12 and Annex F).

### **6.8 Ignition circuit**

External ignition is accomplished by a spark plug powered from a 10 kV transformer. The spark plug shall have a gap of 3 mm. The transformer shall be of a type specifically designed for spark ignition use. The transformer shall have an isolated (unearthed) secondary to minimize interference with the data transmission lines. The electrode length and location of the spark plug shall be such that the spark gap is located 13 mm above the centre of the specimen in the horizontal orientation, in the vertical orientation, the spark plug shall be positioned so that the gap is located in the specimen face plane and 5 mm above the top of the holder.

**6.9 Ignition timer**, capable of recording elapsed time to the nearest second and shall be accurate to within 1 s in 1 h.

**6.10 Oxygen analyser**, paramagnetic type, with a range of 0 % oxygen to 25 % oxygen. The analyser shall exhibit a linear response and drift of not more than  $\pm 50$  parts per million of oxygen (root-mean-square value) over a period of 30 min. Since oxygen analysers are sensitive to stream pressures, the stream pressure shall be regulated (upstream of the analyser) to allow for flow fluctuations and the readings from the analyser compensated with an absolute pressure regulator to allow for atmospheric pressure variations. The analyser and the absolute pressure regulator shall be located in a constant temperature environment. The oxygen analyser shall have a 10 % to 90 % of full-scale response time of less than 12 s.

**6.11 Heat flux meter**, of the Gardon (foil) or Schmidt-Boelter (thermopile) type with a design range of about 100 kW/m<sup>2</sup>. The target receiving radiation, and possibly to a small extent convection, shall be flat, circular, of approximately 12,5 mm in diameter and coated with a durable matt black finish. The target shall be water-cooled.

Radiation shall not pass through any window before reaching the target. The instrument shall be robust, simple to set up and use, and stable in calibration. The instrument shall have an accuracy of within  $\pm 3$  % and a repeatability within 0,5 %.

The calibration of the heat flux meter shall be checked, whenever a recalibration of the apparatus is carried out, by comparison with two instruments of the same type as the working heat flux meter and of similar range held as reference standards and not used for any other purpose (see Annex E). One of the reference standards shall be fully calibrated at a standardizing laboratory at yearly intervals.

This meter shall be used to calibrate the heater (Figure 7 and Figure 8). It shall be positioned at a location equivalent to the centre of the specimen face in either orientation during this calibration.

**6.12 Calibration burner**, constructed from a square-section brass tube with a square orifice covered with wire gauze through which the methane diffuses (Figure 9). The tube is packed with ceramic fibre to improve uniformity of flow. The calibration burner is suitably connected to a metered supply of methane of at least 99,5 % purity.

**6.13 Data collection and analysis system**, having facilities for recording the output from the O<sub>2</sub> analyser, the orifice meter, the thermocouples and the load cell. The data collection system should have an accuracy corresponding to at least 50 parts per million of oxygen for the oxygen channel, 0,5 °C for the temperature measuring channels, and 0,01 % of full-scale instrument output for all other instrument channels. The system should be capable of recording data every 5 s for at least 1 h.

## 7 Suitability of a product for testing

### 7.1 Surface characteristics

A product having one of the following properties is suitable for testing:

- a) an essentially flat exposed surface;
- b) a surface irregularity which is evenly distributed over the exposed surface provided that
  - 1) at least 50 % of the surface of a representative 100 mm square area lies within a depth of 10 mm from a plane taken across the highest points on the exposed surface, or
  - 2) for surfaces containing cracks, fissures or holes not exceeding 8 mm in width nor 10 mm in depth, the total area of such cracks, fissures or holes at the surface does not exceed 30 % of a representative 100 mm square area of the exposed surface.

**NOTE 6** When an exposed surface does not meet the requirements of either 7.1 a) or 7.1 b), the product may be tested in a modified form complying as nearly as possible with the requirements given in 7.1. The test report should state that the product has been tested in a modified form and clearly describe the modification.

### 7.2 Asymmetrical products

A product submitted for this test can have faces which differ or can contain laminations of different materials arranged in a different order in relation to the two faces. If either of the faces can be exposed in use within a room, cavity or void, then both faces shall be tested.

### 7.3 Thin materials

This test method can prove unsuitable for excessively thin materials since insufficient data will be collected for the calculation of heat release rates. For some materials, reducing the data collection interval from 5 s to some shorter value can solve this problem.

### 7.4 Composite specimens

Composite specimens may be tested, provided they are prepared as specified in 8.3.

### 7.5 Dimensionally unstable materials

This test method can prove unsuitable for materials that change their dimensions substantially when exposed to the cone radiation, for example materials that intumesce or shrink away from the cone radiator, because the irradiance on the surface of the specimen at the time of ignition can differ significantly from that set initially. The precision of the method can be worse than that indicated in Annex B for materials that behave in this way.

## 8 Specimen construction and preparation

### 8.1 Specimens

**8.1.1** Unless otherwise specified, three specimens shall be tested at each level of irradiance selected and for each different exposed surface.

**8.1.2** The specimens shall be representative of the product and shall be square with sides measuring  $(100_{-5}^0)$  mm.

**8.1.3** Products with normal thickness of 50 mm or less shall be tested using their full thickness.

**8.1.4** For products with normal thickness of greater than 50 mm, the requisite specimens shall be obtained by cutting away the unexposed face to reduce the thickness to  $(50_{-5}^0)$  mm.

**8.1.5** When cutting specimens from products with irregular surfaces, the highest point on the surface shall be arranged to occur at the centre of the specimen.

**8.1.6** Assemblies shall be tested as specified in 8.1.3 or 8.1.4 as appropriate. However, where thin materials or composites are used in the fabrication of an assembly, the presence of air or an air gap or the nature of any underlying construction can significantly affect the ignition and burning characteristics of the exposed surface.

**NOTE 7** The influence of the underlying layers should be understood and care taken to ensure that the test result obtained on any assembly is relevant to its use in practice.

When the product is a material or composite which would normally be attached to a well defined substrate, then it shall be tested in conjunction with that substrate using the recommended fixing technique, for example, bonded with the appropriate adhesive or mechanically fixed.

**8.1.7** Products that are thinner than 6 mm shall be tested with a substrate representative of end-use conditions, such that the total specimen thickness is 6 mm or more. In the case of specimens of less than 6 mm in thickness and which would be used with an air space adjacent to the unexposed face, the specimens shall be mounted so that there is an air space of at least 12 mm between its unexposed face and the refractory fibre blanket.

NOTE 8 This can be achieved by the use of a metal spacer frame.

### 8.2 Conditioning of specimens

Before the test, specimens shall be conditioned to constant mass at a temperature of  $(23 \pm 2) ^\circ\text{C}$ , and a relative humidity of  $(50 \pm 5) \%$  in accordance with ISO 554.

NOTE 9 Constant mass is considered to be reached when two successive weighing operations, carried out at an interval of 24 h, do not differ by more than 0,1 % of the mass of the test piece or 0,1 g, whichever is the greater.

### 8.3 Preparation

A conditioned specimen shall be wrapped in a single layer of aluminium foil, of 0,03 mm to 0,05 mm thickness, with the shiny side towards the specimen, covering the unexposed surfaces.

Composite specimens shall be exposed in a manner typical of the end-use condition [for example, if used with an air gap (see 8.1.6), an air gap shall be included behind the specimen and within the aluminium foil]. They shall be tested with the retainer frame (see Figure 10, applicable to horizontal orientation testing only) and also prepared so that the sides are enveloped with the outer layer(s) or otherwise protected. If such methods are used, they shall be specified in the test report.

NOTE 10 The use of the retainer frame is recommended for testing in the horizontal orientation.

Figure 11 shows a wire grid suitable for testing specimens which move towards the heater. The exact mounting and retaining method shall be specified in the test report.

## 9 Test environment

The apparatus shall be located in a draught-free environment in an atmosphere of relative humidity of between 20 % and 80 % and a temperature between  $15 ^\circ\text{C}$  and  $30 ^\circ\text{C}$ .

## 10 Calibration

### 10.1 Heater calibration

Adjust the temperature controller so that the conical heater produces the required irradiance, as measured by the heat flux meter, at the start of each test day, when changing to a new irradiance or when the conical heater orientation is changed.

No specimen or specimen holder shall be used when the heat flux meter is inserted into the calibration position. Operate the cone heater for at least 10 min and ensure that the controller is within its proportional band before beginning this calibration.

### 10.2 Oxygen analyser calibration

#### 10.2.1 Preliminary calibrations

**10.2.1.1** Determine the delay time of the oxygen analyser by delivering a methane flow rate equivalent to 5 kW to the calibration burner. The heater shall not be turned on for this calibration. Record the output of the analyser as the methane supply, turned on and ignited, reaches a steady value, and then returns to baseline after the supply is removed. In addition monitor the temperature of the exhaust orifice meter.

The turn-on delay is the time difference between the temperature reading reaching 50 % of its ultimate deflection and the oxygen reading reaching 50 % of its ultimate deflection. Calculate the turn-off delay similarly. The delay time  $t_d$  is the average of at least three turn-on and turn-off delays. The oxygen concentration at a given time shall be taken as the concentration registered after the time interval  $t_d$ .

**10.2.1.2** If the oxygen analyser is equipped with an electric response time adjustment, set it so that at turn-off there is just a trace of overshoot when switching rapidly between two different calibration gases.

**10.2.1.3** The timing of the scans by the data collection system shall be calibrated with a timer accurate to within 1 s in 1 h. The data output shall show event times correct to 3 s.

#### 10.2.2 Operating calibrations

At the start of testing each day, zero and calibrate the oxygen analyser. For zeroing, feed the analyser with nitrogen gas, with the same flow rate and pressure as for the sample gases. Calibration shall be similarly achieved using dried ambient air and adjusting for a response of 20,95 %. Carefully monitor analyser flow rates and set to be equal to the flow rate used when testing specimens. After each specimen has been tested, ensure that a response level of 20,95 % is obtained using ambient air.

### 10.3 Heat release rate calibration

**10.3.1** Perform heat release rate calibration at the start of testing each day. Introduce methane into the calibration burner at a flow rate corresponding to 5 kW based on the net heat of combustion of methane ( $50,0 \times 10^3$  kJ/kg) using a precalibrated flowmeter. The flowmeter used may a dry test meter, a wet test meter or an electronic mass flow controller. If an electronic mass flow controller is used, it shall be calibrated periodically against a dry test meter or a wet test meter. The test meter shall be equipped with devices to measure the temperature and pressure of the flowing gas, so that appropriate corrections to the reading can be made. If a wet test meter is used, the readings shall also be corrected for the moisture content. The exhaust fan shall be set to the speed to be used for subsequent testing. The required calculations are given in clause 12.

NOTE 11 Calibration may be performed with the cone heater operating or not, but should not be performed during heater warm-up.

**10.3.2** At least once a month, perform a further calibration with a flow rate corresponding to 10 kW, using the basic procedure as described in 10.3.1. With the instrument calibrated at 5 kW, the 10 kW calibration shall give a heat release rate value of 10 kW to within  $\pm 5\%$ .

### 10.4 Mass measuring system calibration

The load cell shall be calibrated with standard weight-pieces in the range of test specimen mass at least every day, and when the load cell mechanical zero needs to be adjusted. The load cell mechanical zero may have to be adjusted after changing orientation, due to different specimen holder tare masses.

## 11 Test procedure

**WARNING** — So that suitable precautions are taken to safeguard health, the attention of all concerned in fire tests is drawn to the possibility that toxic or harmful gases can be evolved during exposure of test specimens.

The test procedures involve high temperatures and combustion processes. Therefore, hazards can exist for burns, ignition of extraneous objects or clothing. The operator shall use protective gloves for insertion and removal of test specimens. Neither the cone heater nor the associated fixtures shall be touched while hot except with the use of protective gloves. Care shall be taken never to touch the spark igniter which carries a substantial potential (10 kV). The exhaust system of the apparatus shall be checked for proper operation before testing and shall discharge into a building exhaust system with adequate capacity. The possibility of the violent ejection of molten hot material or sharp fragments from some kinds of specimens when irradiated cannot totally be discounted and it is therefore essential that eye protection be worn.

### 11.1 Initial preparation

**11.1.1** Check the CO<sub>2</sub> trap and the final moisture trap. Replace the sorbents if necessary. Drain any accumulated water in the cold trap separation chamber. The normal operating temperature of the cold trap shall be between 0 °C and 4 °C.

NOTE 12 If any of the traps or filters in the gas sampling line have been opened during the check, the gas sampling should be checked for leaks, for example by introducing pure nitrogen, at the same flow-rate and pressure as for the sample gases, from a nitrogen source connected as close as possible to the ring sampler. The oxygen analyser should then read zero.

**11.1.2** Turn on power to the cone heater (see annex A.4.1) and the exhaust. Power to the gas analysers, load cell and pressure transducer shall not be turned off on a daily basis.

**11.1.3** Set an exhaust flow rate of  $(0,024 \pm 0,002 \text{ m}^3/\text{s})$ . If a different flow-rate is used, this shall be indicated in the test report.

**11.1.4** Perform the required calibration procedures specified in clause 10. In the horizontal orientation, put an empty specimen holder with refractory blanket (6.5.1), in place during warm-up and between tests to avoid excessive heat transmission to the load cell.

NOTE 13 When testing in the vertical orientation, the use of an empty specimen holder is not necessary.

NOTE 14 A retainer frame (Figure 10) and wire grid (Figure 11) should be used when testing intumescent specimens in the horizontal orientation and can also be used to reduce unrepresentative edge burning of composite specimens and for retaining specimens prone to delamination. Other techniques may be utilized if documented in the test report. The wire grid shown in Figure 11 is also suitable for the vertical orientation.

**11.1.5** If external ignition is used, position the spark plug holder in the location appropriate to the orientation being used (6.5).

## 11.2 Procedure

**11.2.1** When ready to test, if testing in the horizontal orientation, first remove the empty specimen holder (see 11.1.4).

**11.2.2** Place the specimen, held in the appropriate holder (6.5), in position and start the data collection (6.13). (The holder shall be at room temperature initially.) The data collection intervals shall be 5 s or less.

**11.2.3** Start the ignition timer (6.9) if external ignition is to be used. Move the spark plug into place and turn on the power.

**11.2.4** Record the times when flashing or transitory flaming occur; when sustained flaming occurs, record the time, turn off the spark and remove the spark igniter. If the flame extinguishes in less than 60 s after turning off the spark, re-insert the spark igniter and turn on the spark, if flaming re-occurs, stop the test, discard the test data and repeat the test without removing the spark until the entire test is completed. Report these events in the test report.

**11.2.5** Collect all data until either:

- a) 2 min after flaming or other signs of combustion cease and the average mass loss over a 1 min period has dropped below 150 g/m<sup>2</sup>; or
- b) 60 min have elapsed;

whichever occurs first. Observe and record physical changes to the sample such as melting, swelling and cracking.

**11.2.6** Remove specimen and specimen holder.

**11.2.7** For testing in the horizontal orientation, replace an empty specimen holder.

**11.2.8** If the specimen does not ignite in 10 min, remove and discard, unless the specimen is showing signs of heat evolution.

**11.2.9** Three specimens shall be tested and the results reported as described in clause 13. The 180 s mean heat release rate readings shall be compared for the three specimens. If any of these mean readings differ by more than 10 % from the arithmetic mean of the three readings, then a further set of three specimens shall be tested. In such cases, the arithmetic mean of the set of six readings shall be reported.

NOTE 15 The test data have limited validity if the specimen melts sufficiently to overflow the drip trough when testing in the vertical orientation or the sample holder when testing in horizontal orientation, if explosive spalling occurs, or if the specimen swells excessively and touches the spark igniter or the heater base plate.

## 12 Calculations

NOTE 16 The equations in this clause assume only O<sub>2</sub> is measured as indicated on the gas analysis system on Figure 6. Appropriate equations for cases where additional gas analysis equipment (CO<sub>2</sub>, CO and possibly H<sub>2</sub>O) is used and CO<sub>2</sub> is not removed from the O<sub>2</sub> sampling lines can be found in Annex F. In any case where CO<sub>2</sub> is removed from the O<sub>2</sub> sampling line (even when CO<sub>2</sub> is measured), equations (1) to (5) should be used.

### 12.1 Calibration constant for oxygen consumption analysis

The methane calibration shall be performed daily to check for the proper operation of the instrument and to compensate for minor changes in determination of mass flow. (A calibration more than 5 % different from the previous one is not normal and suggests instrument malfunction). The calibration constant *C*, is calculated using

$$C = \frac{10,0}{(12,54 \times 10^3)(1,10)} \sqrt{\frac{T_e}{\Delta p}} \frac{1,105 - 1,5x_{O_2}}{x_{O_2}^0 - x_{O_2}} \quad \dots (1)$$

where 10,0 corresponds to 10,0 kW methane supplied,  $12,54 \times 10^3$  is  $\Delta h_c / r_{O_2}$  for methane and 1,10 is the ratio of the molecular weights of oxygen and air.

### 12.2 Heat release rate

**12.2.1** Prior to performing other calculations, calculate the oxygen analyser time shift, *t<sub>d</sub>*, using the following equation:

$$x_{O_2}(t) = x_{O_2}^1(t + t_d) \quad \dots (2)$$

**12.2.2** Calculate the heat release rate, *q̇(t)*, from

$$\dot{q}(t) = (\Delta h_c / r_{O_2})(1,10) C \sqrt{\frac{\Delta p}{T_e}} \frac{x_{O_2}^0 - x_{O_2}}{1,105 - 1,5x_{O_2}} \quad \dots (3)$$

where  $\Delta h_c / r_{O_2}$  for the specimen is taken as  $13,1 \times 10^3$  kJ/kg unless a more accurate value is known.

**12.2.3** Heat release rate per unit area can then be obtained from

$$\ddot{q}''(t) = \dot{q}(t) / A_s \quad \dots (4)$$

where *A<sub>s</sub>* is the initially exposed area of the sample, for example, 0,008 8 m<sup>2</sup> in the vertical orientation and in the horizontal orientation when the retainer frame is used.

### 12.3 Exhaust duct flow rate

The mass flow rate, in kilograms per second, in the exhaust duct is given by

$$\dot{m}_e = C \sqrt{\frac{\Delta p}{T_e}} \quad \dots (5)$$

NOTE 17 Equations for specimen mass loss rate  $\dot{m}$  and effective heat of combustion  $\Delta h_{c,eff}$  are given in Annex C.

### 13 Test report

The test report shall be as comprehensive as possible and shall include any observations made during the test and comments on any difficulties experienced during testing. The units for all measurements shall be clearly stated in the report. Certain units convenient for reporting are suggested below.

The following essential information shall also be given in the test report:

- a) name and address of test laboratory;
  - b) name and address of sponsor;
  - c) name and address of manufacturer/supplier;
  - d) date of the test;
  - e) operator;
  - f) tradename and specimen identification code or number;
  - g) composition or generic identification;
  - h) specimen thickness<sup>2)</sup>, expressed in millimetres, and mass<sup>2)</sup>, expressed in grams. With composites and assemblies a nominal thickness and density of each of the components shall be given, together with the apparent (overall) density of the whole;
  - i) colour of the specimens;
  - j) details of specimen preparation by the testing laboratory;
  - k) test orientation, specimen mounting, face tested and whether the retainer frame, the wire grid, or other special mounting procedures were used;
  - l) irradiance<sup>2)</sup>, expressed in kilowatts per square metre, and exhaust system flow rate<sup>2)</sup>, expressed in cubic metres per second;
  - m) number of replicate specimens tested under the same conditions;
- NOTE 18 This should be a minimum of three, except for exploratory testing.
- n) time to sustained flaming<sup>2)</sup>, expressed in seconds;

o) test duration<sup>2)</sup>, i.e. the time between the start of the test and the end according to 11.2.5, expressed in seconds;

p) heat release rate (per unit area), expressed in kilowatts per square metre, represented as a curve<sup>2)</sup>, recorded for the entire test;

q) average  $\dot{q}''$  value<sup>2)</sup> for the first 180 s ( $\dot{q}''_{180}$ ) and 300 s ( $\dot{q}''_{300}$ ) after ignition, or for other appropriate periods and peak<sup>2)</sup>  $\dot{q}''$  ( $\dot{q}''_{max}$ ), values, expressed in kilowatts per square metre.

For specimens which do not show sustained flaming, report the above quantities tabulated for periods beginning with the next reading after the last negative rate of heat release reading at the beginning of the test.

Certain specimens do not show visible, sustained flaming, but do indicate non-zero rate of heat release values. There will be negative readings, in general, since before the specimen starts burning the output is  $0 \pm$  noise. Average rate of heat release values have to be calculated using the trapezium rule for integration.

For example, with a 5 s data collection interval,  $\dot{q}''_{180}$  is obtained as follows:

- 1) sum the rate of heat release values for the 2<sup>nd</sup> scan to the 36<sup>th</sup> scan after ignition, or to the last negative value. If the test is completed before the 180 s period has elapsed, use the test average instead;
  - 2) add half of the rate of heat release measured at the first scan and at the 37<sup>th</sup> scan after ignition or after the last negative value;
  - 3) multiply the sum obtained in step 2 by the scan interval and divide it by 180;
- r) total heat released by the specimen<sup>2)</sup>, expressed in megajoules per square metre. The total heat shall be computed beginning at the next reading after the last negative rate of heat release reading occurred at the beginning of the test, and continuing until the final reading recorded for the test.

The total heat release is also computed by using the trapezium rule to calculate integrated values. In this case, the first scan to be used is the one after the last negative rate of heat release reading occurring at the beginning of the test;

s) average  $\Delta h_{c,eff}$  for entire test<sup>2)</sup>, expressed in megajoules per kilogram;

t) curve of  $\Delta h_{c,eff}$  (optional)<sup>2)</sup>;

<sup>2)</sup> Report these items for each specimen.


- u) mass remaining after test<sup>3)</sup>, expressed in grams, and percentage of the total mass pyrolysed<sup>3)</sup>;
- v) sample mass loss<sup>3)</sup>, expressed in kilograms per square metre, and the average rate of specimen mass loss per unit area, expressed in grams per square metre second ( $\text{g}/\text{m}^2 \text{ s}$ ), computed over the period between ignition and the end of the test;

w) values determined in items n), o), s), q), r) and v), averaged for all replicates;

x) additional observations, such as transitory flaming or flashing<sup>3)</sup>;


y) difficulties encountered in testing, if any<sup>3)</sup>;


NOTE 19 A suggested summary test report is given in Annex D.




<sup>3)</sup> Report these items for each specimen.


Licensed Copy: sheffieldun sheffieldun, na, Thu Nov 30 08:24:58 GMT+00:00 2006, Uncontrolled Copy, (c) BSI






Dimensions in millimetres










Figure 7 — Exploded view, horizontal orientation






Figure 8 — Exploded view, vertical orientation







## Annex A (informative)

### Commentary and guidance notes for operators

#### A.1 Introduction

This annex aims to provide the test operator and perhaps the user of the test results with background information on the method, the apparatus and the data obtained.

#### A.2 Rate of heat release measurements

**A.2.1** Rate of heat release is one of the most important variables in determining the hazard from a fire. In a typical fire, many items composed of many surfaces contribute to the development of a fire, thus making its evaluation quite complex. A determination should first be made of when each separate surface will ignite, if at all. The size of the fire from any items already burning needs to be known due to its contribution to the external irradiance on nearby items. Flame spread over each surface also needs to be evaluated. The rate of heat release from the whole surface may then be determined knowing the rate of heat release per unit area for a given irradiance, as a function of time, as evaluated using this bench scale test. The total fire output then involves a summation over all surfaces for all materials.

**A.2.2** Factors which complicate the calculation of the heat output of a fire are:

- a) the different burning durations for each individual material involved;
- b) the geometry of each surface;
- c) the burning behaviour of the material i.e. melting, dripping or structural collapse.

**A.2.3** The test method does not prescribe the irradiance levels, orientation and whether external ignition is to be used. These should be determined separately for each product to be assessed. For given applications and products a comparison with some full scale fires is generally necessary to determine the time period over which heat release is to be calculated.

For exploratory testing, it is recommended to use the horizontal orientation, the spark igniter and an irradiance value of 35 kW/m<sup>2</sup> initially; in the absence of further specifications from the sponsor, tests at 25 kW/m<sup>2</sup>, 35 kW/m<sup>2</sup>, and 50 kW/m<sup>2</sup> are recommended. Results obtained may then suggest whether additional testing at different irradiance levels is desirable.

The test results may not be statistically significant unless the irradiance used is substantially (10 kW/m<sup>2</sup>) higher than the minimum irradiance level needed for sustained flaming to occur for that specimen.

#### A.3 Choice of operating principle

**A.3.1** A number of apparatuses have been developed for measuring rate of heat release. Traditionally, the simplest is a direct measurement of flow enthalpy from a chamber thermally lagged to present an adiabatic environment. A truly adiabatic apparatus, with the use of guard heaters, would be possible, but would be prohibitively expensive. A combustion chamber that is insulated in a simpler manner leads to a significant under-measurement of the heat release, so that only an empirical calibration is possible. Furthermore, that calibration can be sensitive to the sootiness of the combustible. A more advanced scheme is an isothermal instrument, with the heat release rate taken to be that which has to be supplied by a substitution burner to maintain isothermal conditions. This scheme gives better results, however, its practical implementation is complex and costly.

**A.3.2** It is difficult to measure heat directly without some loss. However, it is simple to contain the total products of combustion without loss and to measure the oxygen concentration in that stream. Heat release can be computed from such measurements using the oxygen consumption principle. This principle states that for most common combustibles an amount of heat equal to  $13,1 \times 10^3$  kJ is released for each kilogram of oxygen consumed from the air stream. This quantity varies by about  $\pm 5\%$  for most common combustibles. This principle forms the basis of the test method detailed in this International Standard. The method remains useful even if a significant fraction of the products become CO or soot rather than CO<sub>2</sub>; in these cases, correction factors can be applied.

Excessively high CO concentrations which could result from a restricted oxygen supply, cannot occur under the normal operating conditions of this test method since oxygen intake is not restricted.

#### A.4 Heater design

**A.4.1** Experience with various rate-of-heat-release measurement techniques suggests that for minimal errors in irradiance, the specimen should see only either a thermostatically controlled heater, a water-cooled plate or open air. Nearby solid surfaces, if they are not temperature-controlled, can rise in temperature due to specimen flame heating and then act as further sources of radiation back to the specimen which can lead to errors. Furthermore, when oxygen consumption is used as the measurement principle, a gas-fired heater is not desirable because it can contribute a noisy baseline to oxygen readings, even though allowance can be made for its oxygen consumption.

**A.4.2** The heater, in the shape of a truncated cone, initially developed for ISO 5657 has been modified to include higher irradiances, temperature control, flow streamline improvement and to be of a more rugged design. In the horizontal orientation, the conical shape approximately follows the fire plume contours while the central hole allows the stream to emerge without impacting on the heater. Air entrainment ensures the flames do not reach the sides of the cone.

**A.4.3** Due to the shape of the heater, the apparatus is commonly referred to as the cone calorimeter.

#### A.5 Pilot ignition

Ignition of test specimens in many apparatuses is achieved by a gas pilot. This however can present difficulties when assessing heat release due to its contribution to heat output, deterioration of orifices and sooting. Its design is also difficult since it needs to be centrally located and resistant to extinguishment by draughts and fire retardants, and most importantly, should not apply additional heat to the specimen. An electric spark is free of most of these difficulties and has therefore been adopted as the igniter. The spark igniter requires only occasional cleaning and adjustment of the electrodes.

#### A.6 Back face conditions

The heat losses through the back face of the specimen can have an influence of the burning rate near the end of its burning time. For reproducible measurements the loss through the back face should be standardized and this is achieved by using a layer of insulating material.

### Annex B (informative) Resolution, precision and bias

#### B.1 Resolution

Methane calibration studies have shown typical fluctuations of  $\pm 1,5\%$  in rate of heat release with a linearity to within 5 % over a range of 1 kW to 12 kW and within 2 % over a range of 5 kW to 12 kW. Calibrations with other gases show similar results. Calibration gases can be delivered to the burner at a steady rate. The uniformity of solid-fuel combustion, however, is governed by the pyrolysis at the surface, which can under some circumstances show substantial fluctuations. For instance, the fluctuations for poly(methyl methacrylate) are typically greater than for wood products. With solid materials, therefore, the resolution is determined by the specimen pyrolysis process, rather than by instrument limits.

#### B.2 Speed of response

The limits to the speed of response of any technique for measuring heat release rate are set by the slowest responding element. With this method this is the oxygen analyser. Response times of the pressure transducer and thermocouple are usually considerably faster.

#### B.3 Precision

A set of inter-laboratory trials have been conducted by ISO/TC 92/SC 1/WG 5. The protocol used was functionally the same as described in this International Standard. The materials tested in these trials were 25 mm black PMMA ( $\rho = 1\,180\text{ kg/m}^3$ ), 30 mm rigid polyurethane foam ( $\rho = 33\text{ kg/m}^3$ ), 13 mm particle board ( $\rho = 640\text{ kg/m}^3$ ), 3 mm hardboard ( $\rho = 1\,010\text{ kg/m}^3$ ), 10 mm gypsum board ( $\rho = 1\,110\text{ kg/m}^3$ ) and 10 mm fire retardant treated particle board ( $\rho = 750\text{ kg/m}^3$ ). Three replicates of each material were tested in two orientations (horizontal and vertical) and at two irradiance levels ( $25\text{ kW/m}^2$  and  $50\text{ kW/m}^2$ ) by six to eight laboratories.

Data from the ISO trials were supplemented by data developed during an analogous set of trials conducted by ASTM E05 SC21 TG 60, again using functionally the same protocol and identical irradiance levels, orientations and number of replicates. Since the findings for repeatability,  $r$  and reproducibility  $R$  in the ASTM trials showed generally similar trends, the data were analysed as a combined data set. ASTM data were excluded in the one instance (i.e., for  $q''_{180}$ ) where instructions to the laboratories differed. Six laboratories tested the following materials: 6 mm fire-retardant treated ABS ( $\rho = 325 \text{ kg/m}^3$ ), 12 mm particle board<sup>4)</sup> ( $\rho = 640 \text{ kg/m}^3$ ), 6 mm black PMMA<sup>5)</sup> ( $\rho = 1\,180 \text{ kg/m}^3$ ), 6 mm polyethylene ( $\rho = 800 \text{ kg/m}^3$ ), 6 mm PVC ( $\rho = 1\,340 \text{ kg/m}^3$ ), and 25 mm rigid polyisocyanurate foam ( $\rho = 280 \text{ kg/m}^3$ ).

Values for repeatability  $r$  and reproducibility  $R$  at the 95 % confidence level were calculated for the complete data set in accordance with ISO 5725 for five variables. Such values for  $r$  and  $R$  are equal to 2,8 times the appropriate standard deviation and include results identified as “stragglers”. The variables were chosen as being representative for the test results:  $t_{\text{ig}}$ ,  $q''_{\text{max}}$ ,  $q''_{180}$ ,  $q''_{\text{tot}}$  and  $\Delta h_{\text{c,eff}}$ . A linear regression model [equation II in ISO 5725:1986, 15.2 b)] was used to describe  $r$  and  $R$  as a function of the mean over all replicates and over all laboratories of each of the five aforementioned variables. The regression equations are given below. The range of mean values over which the fit was obtained is also indicated.

The results for  $t_{\text{ig}}$  in the range 5 s to 150 s were

$$r = 4,1 + 0,125 t_{\text{ig}} \quad \dots \text{ (B.1)}$$

$$R = 7,4 + 0,220 t_{\text{ig}} \quad \dots \text{ (B.2)}$$

The results for  $q''_{\text{max}}$  in the range of 70 kW/m<sup>2</sup> to 1 120 kW/m<sup>2</sup> were

$$r = 13,3 + 0,131 q''_{\text{max}} \quad \dots \text{ (B.3)}$$

$$R = 60,4 + 0,141 q''_{\text{max}} \quad \dots \text{ (B.4)}$$

The results for  $q''_{180}$  in the range of 70 kW/m<sup>2</sup> to 870 kW/m<sup>2</sup> were

$$r = 23,3 + 0,037 q''_{180} \quad \dots \text{ (B.5)}$$

$$R = 25,5 + 0,151 q''_{180} \quad \dots \text{ (B.6)}$$

The results for  $q''_{\text{tot}}$  in the range of 5 MJ/m<sup>2</sup> to 720 MJ/m<sup>2</sup> were

$$r = 7,4 + 0,068 q''_{\text{tot}} \quad \dots \text{ (B.7)}$$

$$R = 11,8 + 0,088 q''_{\text{tot}} \quad \dots \text{ (B.8)}$$

The results for  $\Delta h_{\text{c,eff}}$  in the range of 7 kJ/g to 40 kJ/g were

$$r = 1,23 + 0,050 \Delta h_{\text{c,eff}} \quad \dots \text{ (B.9)}$$

$$R = 2,42 + 0,055 \Delta h_{\text{c,eff}} \quad \dots \text{ (B.10)}$$

The meaning of these equations is best illustrated by means of an example. Suppose a laboratory tests a single sample of a certain material and determines that the time to ignition is 100 s. If the same laboratory now conducts a second test on the same material, the value of  $r$  is evaluated as

$$r = 4,1 + 0,125 \times 100 \equiv 17 \text{ s}$$

Then the probability is 95 % that the result of the second test will fall between 83 s and 117 s. Suppose now that the same material is tested by a different laboratory. The value of  $R$  is evaluated as

$$R = 7,4 + 0,220 \times 100 \equiv 29 \text{ s}$$

Then the probability is 95 % that the results from the test at that laboratory will fall between 71 s and 129 s.

<sup>4)</sup> This was the same material as tested by the ISO group.

<sup>5)</sup> This was the same material by the tested by the ISO group but in a different thickness.

#### B.4 Bias

For solid specimens of unknown chemical composition, as used in building materials, furnishings, etc., it has been documented that the use of the oxygen consumption standard value of  $\Delta h_c/r_o = 13,1 \times 10^3$  kJ/kg oxygen, results in an expected error band of  $\pm 5$  %. For homogeneous materials with only a single pyrolysis mechanism, this uncertainty can be reduced by determining  $\Delta h_c$  from oxygen bomb measurements and  $r_o$  from ultimate elemental analysis. For most testing, this is not practical since specimens are usually composites, non-homogeneous or exhibit several degradation reactions. For reference materials, however, careful determination of  $\Delta h_c/r_o$  can make this source of uncertainty substantially less.

### Annex C (informative)

#### Mass loss rate and effective heat of combustion

##### C.1 Effective heat of combustion

The effective heat of combustion is a constant during combustion of homogeneous specimens having only a single mode of degradation and is less than the value of the theoretical net heat of combustion. Examples of a material with a single mode of degradation and, therefore, a constant effective heat of combustion include most organic liquids. Cellulosic products, by contrast, typically show more than one mode of degradation and a varying effective heat of combustion. For materials having more than one mode of degradation, or for composites or non-homogeneous materials, the effective heat of combustion is not necessarily constant. Effective heat of combustion and mass loss rate can be used to provide additional information on the fire behaviour of materials.

##### C.2 Calculation

The mass loss rate,  $-\dot{m}$  computed for each time interval starting from time of ignition, can be used to determine a time-varying value of the effective heat of combustion:

$$\Delta h_{c, \text{eff}}(t) = \frac{\dot{q}(t)}{-\dot{m}} \quad \dots \text{ (C.1)}$$

The required mass loss rate,  $-\dot{m}$ , at each time interval can be calculated using the following five-point numerical differentiation equations

For the first scan ( $i = 0$ ):

$$-\dot{m}_{i=0} = \frac{25m_0 - 48m_1 + 36m_2 - 16m_3 + 3m_4}{12\Delta t} \quad \dots \text{ (C.2)}$$

For the second scan ( $i = 1$ ):

$$-\dot{m}_{i=1} = \frac{10m_0 + 3m_1 - 18m_2 + 6m_3 - m_4}{12\Delta t} \quad \dots \text{ (C.3)}$$

For any scan for which  $1 < i < n - 1$  ( $n$  = total number of scans):

$$-\dot{m}_i = \frac{-m_{i-2} + 8m_{i-1} - 8m_{i+1} + m_{i+2}}{12\Delta t} \quad \dots \text{ (C.4)}$$

For the last scan but one ( $i = n - 1$ ):

$$-\dot{m}_{i=n-1} = \frac{-10m_n - 3m_{n-1} + 18m_{n-2} - 6m_{n-3} + m_{n-4}}{12\Delta t} \quad \dots \text{ (C.5)}$$

For the last scan ( $i = n$ ):

$$-\dot{m}_{i=n} = \frac{-25m_n + 48m_{n-1} - 36m_{n-2} + 16m_{n-3} - 3m_{n-4}}{12\Delta t} \quad \dots \text{ (C.6)}$$

As the mass loss rate requires numerical differentiation for its determination and is, therefore, noisier than measurements obtained directly from instrument readings, it is better to calculate mean values of  $\Delta h_{c,\text{eff}}$ . To obtain such values, the mean values of the numerator and denominator in (C.1) need to be calculated separately rather than calculating the mean of the ratio. For instance, the mean value of  $\Delta h_{c,\text{eff}}$  over the whole test is given by

$$\Delta h_{c,\text{eff}} = \frac{\sum \dot{q}(t) \Delta t}{m_i - m_f} \quad \dots \text{ (C.7)}$$

The summation is taken over the entire test length from the time of ignition.

The final mass is the last mass reading recorded for the test. To determine the initial mass can be difficult since it takes some finite amount of time for the load cell to settle down, once the specimen is placed upon it. The following procedure should be used.

- a) Make sure that the damping of the load cell is correctly adjusted (critical damping).
- b) For each test, find the maximum value of mass indicated during the first five scans. Record the maximum value as the initial mass and record this value as the mass for all scans prior to that used for the initial mass.

**Annex D (informative)**  
**Summary of test report**

---

Name of laboratory .....	Laboratory reference No. ....
Address: .....	Date of test .....
Telephone No. ....	Telex No. ....

---

**ISO 5660 test report**

---

Sponsor: .....

Address: .....

Manufacturer/supplier: .....

---

**Description of products**

Materials, composite or assembly .....

Trade name and/or reference No. ....

Colour .....

Composition of construction .....

Thickness .....

Area density, kg/m<sup>2</sup> .....

Mass of conditioned specimen, excluding backing and foil wrapping (mean) .....

Face subjected to test .....

Other information relating to specimen .....

.....

Test orientation .....

Retainer frame/wire grid used .....

Exhaust system flow rate (nominal) .....

Irradiance level .....

---

Licensed Copy: sheffieldun sheffieldun, na, Thu Nov 30 08:24:58 GMT+00:00 2006, Uncontrolled Copy, (c) BSI

## Test results

NOTE 1 These test results relate only to the behaviour of the test specimens under the particular conditions of the test; They are not intended to be the sole criterion for assessing the potential fire hazard of the product in use.

NOTE 2 Complete test details may be available from the sponsor.

Specimen	Mass (g)	Thickness (mm)	Time to ignition (s)	Total $q''$ (MJ/m <sup>2</sup> )	Average $\dot{m}''$ (g/m <sup>2</sup> /s)
(1)					
(2)					
(3)					
(4)					
(5)					
(6)					

Mean

Specimen	180 s mean $\dot{q}''$ (kW/m <sup>2</sup> )	300 s mean $\dot{q}''$ (kW/m <sup>2</sup> )	Maximum $\dot{q}''$ (kW/m <sup>2</sup> )	$\Delta h_{c,eff}$ (MJ/kg)
(1)				
(2)				
(3)				
(4)				
(5)				
(6)				

Mean

Observations:

## Annex E (informative)

### Calibration of the working heat flux meter

The inter-comparison of working and reference standard that flux meters specified in 6.11 may be made using the conical heater (6.1), with each heat flux meter mounted in turn in the calibration position, care being taken to allow the whole apparatus to attain thermal equilibrium. Alternatively, a specially built comparison apparatus may be used (for example, that specified in British Standard BS 6809:1987).

The use of two, rather than one, reference standards provides a greater safeguard against change in sensitivity of the reference instruments.

## Annex F (informative)

### Calculation of heat release with additional gas analysis

#### F.1 General

The equations in clause 12 to calculate heat release rate assume that CO<sub>2</sub> is removed from the gas sample in a chemical scrubber before O<sub>2</sub> is measured, as indicated in Figure 6. Some laboratories are equipped to measure CO<sub>2</sub>; in which case it is not necessary to remove the CO<sub>2</sub> from the O<sub>2</sub> line giving the advantage that the use of chemical scrubbing agent, which is costly and requires careful handling, can be avoided.

In this annex, equations are given which are to be used when CO<sub>2</sub> is measured but not scrubbed out of the sampling line. Two cases are considered:

- in the first case, part of the dried and filtered sample stream is diverted into infrared CO<sub>2</sub> and CO analysers (see option in Figure 6),

— in the second case, a water vapour analyser is also added.

To avoid condensation, the measurement of H<sub>2</sub>O concentration in the flow of combustion products requires a separate sampling system with heated filters, heated sampling lines and heated analyser.

## F.2 Symbols

The following new symbols are used in this annex:

$M_a$	molecular mass of air, expressed in kilograms per kilomole (kg/kmol)
$M_e$	molecular mass of the combustion products, expressed in kilograms per kilomole (kg/kmol)
$t_d^1$	delay time of the CO <sub>2</sub> analyser, expressed in seconds (s)
$t_d^2$	delay time of the CO analyser, expressed in seconds (s)
$t_d^3$	delay time of the H <sub>2</sub> O analyser, expressed in seconds (s)
$x_{CO_2}^0$	initial CO <sub>2</sub> reading
$x_{CO}^0$	initial CO reading
$x_{H_2O}^0$	initial H <sub>2</sub> O reading
$x_{O_2}^a$	ambient O <sub>2</sub> mole fraction
$x_{CO_2}^1$	CO <sub>2</sub> reading before delay time correction
$x_{CO}^1$	CO reading before delay time correction
$x_{H_2O}^1$	H <sub>2</sub> O reading before delay time correction
$x_{CO_2}$	CO <sub>2</sub> reading, expressed as a mole fraction
$x_{CO}$	CO reading, expressed as a mole fraction
$x_{H_2O}$	H <sub>2</sub> O reading, expressed as a mole fraction
$\phi$	oxygen depletion factor

## F.3 Case where CO<sub>2</sub> and CO are measured

Just as for the oxygen analyser, measurements of CO<sub>2</sub> and CO should be time-shifted to take transport time in the sampling lines into account:

$$x_{O_2}(t) = x_{O_2}^1(t + t_d) \quad \dots \text{(F.1)}$$

$$x_{CO_2}(t) = x_{CO_2}^1(t + t_d^1) \quad \dots \text{(F.2)}$$

$$x_{CO}(t) = x_{CO}^1(t + t_d^2) \quad \dots \text{(F.3)}$$

Here, the delay times  $t_d^1$  and  $t_d^2$  for the CO<sub>2</sub> and CO analysers respectively are usually different (smaller) than the delay time  $t_d$  for the O<sub>2</sub> analyser.

The exhaust duct flow rate is calculated in the same way as in 12.3:

$$\dot{m}_e = C \sqrt{\frac{\Delta p}{T_e}} \quad \dots (F.4)$$

The rate of heat release can now be determined from

$$\dot{q} = 1,10 \left[ \frac{\Delta h_c}{r_o} \right] x_{O_2}^a \left[ \frac{\phi - 0,172(1-\phi)x_{CO}/x_{O_2}}{(1-\phi) + 1,105\phi} \right] \dot{M}_e \dots \quad \dots (F.5)$$

The oxygen depletion factor  $\phi$  follows from

$$\phi = \frac{x_{O_2}^0(1-x_{CO_2}-x_{CO}) - x_{O_2}(1-x_{CO_2}^0)}{x_{O_2}^0(1-x_{CO_2}-x_{CO}-x_{O_2})} \quad \dots (F.6)$$

The ambient mole fraction of oxygen is:

$$x_{O_2}^a = (1-x_{H_2O}^0)x_{O_2}^0 \quad \dots (F.7)$$

The second term in the denominator of the term in brackets in equation (F.5) is a correction for incomplete combustion of some carbon to CO instead of CO<sub>2</sub>. In cone calorimeter tests,  $x_{CO}$  is usually very small so that it can be neglected in (F.5) and (F.6). The practical implication of this is that a CO analyser will generally not result in a noticeable increase in accuracy of heat release rate measurements. Consequently equations (F.5) and (F.6) can be used even if no CO analyser is present, assuming  $x_{CO}$  is negligible.

#### F.4 Case where H<sub>2</sub>O is also measured

In an open combustion system, such as used in this method, the flow rate of air entering the system cannot be measured directly but is inferred from the flow rate measured in the exhaust duct. An assumption is required regarding the expansion due to combustion of the fraction of the air which is fully depleted of its oxygen. This expansion depends on the composition of the fuel and the actual stoichiometry of the combustion. A good representative value for the volumetric expansion factor is 1,105, which is correct for methane.

This number is already incorporated within the equations for  $\dot{q}$  in 12.2.2 and (F.6). For cone calorimeter tests it can be assumed that over 99 % of the combustion products consist of O<sub>2</sub>, CO<sub>2</sub>, CO, H<sub>2</sub>O and non-reacting gases (which enter and leave the system chemically unaltered) denoted as N<sub>2</sub>. If H<sub>2</sub>O is measured in the exhaust, this together with the O<sub>2</sub>, CO<sub>2</sub> and CO measurements (all three referred to the dry gas) can be used to determine the expansion. The mass flow rate in the exhaust duct is then more accurately given by the following equation:

$$\dot{m}_e = \sqrt{M_e / M_a} C \sqrt{\frac{\Delta p}{T_e}} \quad \dots (F.8)$$

In this equation,  $M_a$  can be taken as 29 g/mol.

NOTE 20 Equations (F.4), (F.5) and (F.8) are derived in Parker[5].

The molecular weight of the combustion products,  $M_e$ , can be calculated from

$$M_e = [4,5 + (1-x_{H_2O})(2,5 + x_{O_2} + 4x_{CO_2})]^4 \quad \dots (F.9)$$

The heat release rate then follows from

$$\dot{q}(t) = 1,10 \left[ \frac{\Delta h_c}{r_o} \right] (1 - x_{\text{H}_2\text{O}}) \left[ \frac{x_{\text{O}_2}^0 (1 - x_{\text{O}_2} - x_{\text{CO}_2})}{1 - x_{\text{O}_2}^0 - x_{\text{O}_2}^0} - x_{\text{O}_2} \right] \dot{m}_e \quad \dots \text{(F.10)}$$

It should be noted that the H<sub>2</sub>O readings must be time-shifted in a similar way as in (F.1) to (F.3) for the other analysers:

$$x_{\text{H}_2\text{O}}(t) = x_{\text{H}_2\text{O}}^1(t + t_d^3) \quad \dots \text{(F.11)}$$

## Annex G (informative)

### Bibliography

- [1] ISO 5657:1986, *Fire tests — Reaction to fire — Ignitability of building products*.
- [2] ISO 5725:1986, *Precision of test methods — Determination of repeatability and reproducibility for a standard test method by inter-laboratory tests*.
- [3] BS 6809:1987, *Method for calibration of radiometers for use in fire testing*.
- [4] ASTM E 1354-90, *Standard test method for heat and visible smoke release rates for materials and products using an oxygen consumption calorimeter*.
- [5] PARKER W.J., *Calculations of the heat release rate by oxygen consumption for various applications*. NBSIR 81-2427-1, March 1982.

## List of references

See national foreword.

**BS 476-15:  
1993  
ISO 5660-1:  
1993**

---

---

## **BSI — British Standards Institution**

BSI is the independent national body responsible for preparing British Standards. It presents the UK view on standards in Europe and at the international level. It is incorporated by Royal Charter.

### **Revisions**

British Standards are updated by amendment or revision. Users of British Standards should make sure that they possess the latest amendments or editions.

It is the constant aim of BSI to improve the quality of our products and services. We would be grateful if anyone finding an inaccuracy or ambiguity while using this British Standard would inform the Secretary of the technical committee responsible, the identity of which can be found on the inside front cover. Tel: 020 8996 9000. Fax: 020 8996 7400.

BSI offers members an individual updating service called PLUS which ensures that subscribers automatically receive the latest editions of standards.

### **Buying standards**

Orders for all BSI, international and foreign standards publications should be addressed to Customer Services. Tel: 020 8996 9001. Fax: 020 8996 7001.

In response to orders for international standards, it is BSI policy to supply the BSI implementation of those that have been published as British Standards, unless otherwise requested.

### **Information on standards**

BSI provides a wide range of information on national, European and international standards through its Library and its Technical Help to Exporters Service. Various BSI electronic information services are also available which give details on all its products and services. Contact the Information Centre. Tel: 020 8996 7111. Fax: 020 8996 7048.

Subscribing members of BSI are kept up to date with standards developments and receive substantial discounts on the purchase price of standards. For details of these and other benefits contact Membership Administration. Tel: 020 8996 7002. Fax: 020 8996 7001.

### **Copyright**

Copyright subsists in all BSI publications. BSI also holds the copyright, in the UK, of the publications of the international standardization bodies. Except as permitted under the Copyright, Designs and Patents Act 1988 no extract may be reproduced, stored in a retrieval system or transmitted in any form or by any means – electronic, photocopying, recording or otherwise – without prior written permission from BSI.

This does not preclude the free use, in the course of implementing the standard, of necessary details such as symbols, and size, type or grade designations. If these details are to be used for any other purpose than implementation then the prior written permission of BSI must be obtained.

If permission is granted, the terms may include royalty payments or a licensing agreement. Details and advice can be obtained from the Copyright Manager. Tel: 020 8996 7070.

BSI  
389 Chiswick High Road  
London  
W4 4AL